



CITY OF LONGVIEW PURCHASING DIVISION

Addendum No 1

April 17, 2019

1819-36 Laboratory Analysis Services

The City received the following questions:

1. Sec 5 – Technical Specifications:

“Analyses must be completed within 3-4 days of receiving.” If the sample matrix has a significant amount of algae, the analysis time may be extended. Will a report turnaround time of 10-business days from sample receipt in the lab be acceptable?

Answer: As the bid states, analyses must be completed within 3-4 days of receiving.

2. Sec 5 – Technical Specifications:

“Samples must be analyzed to Method ...and SM 6040D...” Would Method SM 6040E be acceptable for Taste & Odor analysis?

Answer: SM6040E would be acceptable for Taste & Odor analysis.

3. Sec 5 – Technical Specifications:

“Algae count must be performed in cells/mL.” Current method used (FlowCam), counts in units/mL. Would this be acceptable?

Answer: Current results' units are #/ml. In the matter of this bid, cells, units, and #s appear to be the same.

If you have any further questions, please contact the Purchasing Department.

Jaye Latch
Purchasing Manager
PO Box 1952
Longview, TX 75606
903-237-1324

Posted – April 17, 2019