



ADDENDUM NO. 2

TO: ALL PLAN HOLDERS
DATE: 08-11-2021
FROM: CITY OF LONGVIEW
BROUGHTON RECREATION CENTER RE-COVER ROOF INSTALLATION

The plans, specifications, and contract documents are modified as described below. All bidders shall acknowledge receipt of this and all other addenda on page P-3 of the Bid Proposal. This addendum becomes a part of the contract documents. All provisions of the original plans, specifications, and contract documents shall remain in full force and effect, except as modified by this addendum.

1. Regarding Pg. NB-1, Notice to Bidders. Time of completion shall be 45 days, including Saturdays, Sundays, and legal holidays.
The City may consider time extensions for material delays that are due to the current market conditions and supply shortages. Contractor must provide proof that the delay time is beyond the Contractor's control and that no other suppliers have available material that meets specifications. Other proof may be requested by the City to prove the contractor has been diligent in ordering materials.
2. Regarding site visits of the project location.
Site visits will be available by appointment only on Thursday August 12, 2021 between 1:00pm & 4:00pm. Scheduling a site visit will be handled through the City of Longview Facility Services supervisor Shawn Hagenbucher, his contact details are below.
3. Regarding the question: What is the roof deck material made of? Information provided by the Architect: It is a smooth modified built-up roof with 1.5" perlite insulation on 22 gage corrugated type A metal roof deck. Photos of the core are attached to this addendum, see pg. 2.

Shawn Hagenbucher
Facility Services supervisor
903-237-1369
Shagenbucher@LongviewTexas.Gov

